



# 防爆合格证

证号: GYB14.1251X

由 深圳市摩控自动化设备有限公司 制造的产品:  
(地址: 深圳市南山区南头关口二路智恒战略性新兴产业园26栋2楼)

名称 角行程电动执行器

型号规格 MAQ-2

防爆标志 Ex d II B T4 Gb

产品标准 Q/MC 1001-2014

图样编号 MC-MAQ-035-00

经图样及技术文件的审查和样品检验, 确认上述产品符合 GB 3836.1-2010、GB 3836.2-2010 标准, 特颁发此证。

本证书有效期: 2014年5月5日至2019年5月4日

- 备注
1. 安全使用注意事项见使用说明书。
  2. 证书编号后缀“X”表明产品具有安全使用特殊条件: 涉及隔爆接合面的维修须联系产品制造商。
  3. 型号规格说明: ■代表额定负载, 可为010、016、024、035、050、080或110。
  4. 紧固件性能等级: A2-70。

站长

国家级仪器仪表防爆安全监督检验站

颁发日期二〇一四年五月五日

本证书仅对与认可文件和样品一致的产品有效。

地址: 上海市漕宝路103号  
邮编: 200233

网址: [www.nepsi.org.cn](http://www.nepsi.org.cn)  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

电话: +86 21 64368180  
传真: +86 21 64844580





# EXPLOSION PROTECTION

## CERTIFICATE OF CONFORMITY

Cert NO.GYB14.1251X

This is to certify that the product

**Electronic Actuator**

manufactured by **SHENZHEN MORC CONTROLS CO., LTD**  
(Address:2nd Floor, Unit 26, Wisdomland Business Park, Nanshan, Shenahen, China)

which model is **MAQ-2**

Ex marking **Ex d II B T4 Gb**

product standard **Q/MC 1001-2014**

drawing number **MC-MAQ-035-00**

has been inspected and certified by NEPSI, and that it conforms to **GB 3836.1-2010,GB 3836.2-2010**

This Approval shall remain in force until **2019.05.04**

**Remarks**

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use:Contact the original manufacturer when repair work relates to the flamepath.
- 3.Model designation: **2** means rated load, which can be 010, 016, 024, 035, 050, 080 or 110.
- 4.Fastener performance level: A2-70.

**Director**

**National Supervision and Inspection Centre for  
Explosion Protection and Safety of Instrumentation**

Issued Date **2014.05.05**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road  
Shanghai 200233, China

<http://www.nepsi.org.cn>  
Email: [info@nepsi.org.cn](mailto:info@nepsi.org.cn)

Tel: +86 21 64368180  
Fax: +86 21 64844580